

Month April**Raspberry Falls Well Water Plant**Year 2011**Additional Testing to Evaluate Possible Surface Water Influence to #2 Well**

Date	Well #2 water usage GPD	Rain Gauge Reading	PH	Temperature	Conductivity	RAW WATER MPN - TC	RAW WATER MPN - EC	Turbidity	Amount pumped just prior to testing.	CL2 Residual
1	20600	0.00								
2	31300	0.00								
3	41500	0.10								
4	34400	0.61	7.7	12.8	201.8	<1	<1	0.06	2500	1.6
5	32000	0.02								
6	32300	0.00								
7	27500	0.03								
8	26700	0.27								
9	31300	0.10								
10	37800	0.10								
11	36600	0.97	7.7	13.1	222.6	<1	<1	0.13	3200	1.5
12	28200	0.51								
13	30500	0.00								
14	46000	0.00								
15	26300	0.28								
16	31100	1.40								
17	34700	0.01								
18	23800	0.01	7.6	13.2	214.1	<1	<1	0.17	2600	1.4
19	24200	0.25								
20	33200	0.00	7.6	13.2	215.2	<1	<1	0.06	2300	1.4
21	33100	0.00	7.7	12.5	204.8	<1	<1	0.11	2100	0.03
22	32800	0.48	7.7	13.1	226.6	2.0	<1	0.10	2200	1.3
23	32900	0.13								
24	33300	0.50								
25	25200	0.00	7.8	13.0	205.4	<1	<1	0.41	2100	1.6
26	45400	0.00								
27	34900	2.70								
28	38600	0.51								
29	37900	0.00								
30	17700	0.00								
31										
AVG	32060	0.3	7.7	13.0	212.9	2.0	#DIV/0!	0.149	2429	1.3
TOT	961800	9.0	53.8	90.9	1490.5	2.0	0.0	1.040	17000	8.8
MAX	46000	2.7	7.8	13.2	226.6	2.0	0.0	0.410	3200	1.6

Comments and observations: