



## **Invitation for Bid**

IFB #2011-052-240

**REVISED BID DUE DATE: February 2, 2012**

<b>ADDENDUM No. 1</b>
-----------------------

**CONTRACTOR'S MUST ACKNOWLEDGE RECEIPT OF THIS ADDENDUM WITH YOUR BID**

**Odorous Air Pipe Repair**

**Addendum Issued: January 26, 2012**

**Invitation for Bid**  
IFB Issued: January 12, 2012  
Odorous Air Pipe Repair  
**ADDENDUM NO. 1**  
**IFB #2011-052-240**

**PURPOSE**

This Addendum supplements, modifies, deletes from, or adds to the original Invitation for Bid and all of the requirements of the addendum are herein made a part of the IFB and any resulting contract documents.

**1. The BID Due Date has been extended.**

Extended Bid Due Date: Thursday, February 2, 2012  
and Time: 3:00 p.m. (Eastern Time)

**2. Section 5, CONTRACT CONDITIONS:**B. Contract Period

**Replace:** The contract shall cover the period from February 15, 2012 (or upon contract approval) through March 31, 2012, or an equivalent period depending upon date of contract award.

**With:** The Contractor shall complete the Work no later than March 31, 2012.

W. Licensure (Addition)

It is the contractor's responsibility to comply with the rules and regulations issued by state regulatory agencies. By my submission of this solicitation, I certify that this firm/individual and subcontractors is properly licensed for providing the goods/services specified.

Identify license number and type below:

1. License #: \_\_\_\_\_

2. Type: \_\_\_\_\_

An unlicensed vendor submitting a bid or proposal where such license is required will be considered nonresponsive and is in violation of state law.

**3. RESPONSES TO QUESTIONS****A. Does the existing pipe inside the manhole get cut out?****RESPONSE:**

*The existing pipe is to be cut and tied into the new manhole. The existing pipe between the new manhole and station is to be abandoned.*

- B.** Where is the chemical pipe shown?

**RESPONSE:**

*Duel two-inch (2") lines, northern most entering the station. "Note 2" on Appendix A is pointing to them.*

- C.** What size diameter are the core drills into the tank?

**RESPONSE:**

Two – 18" core

- D.** What are the exact elevations for top, inverts and based for stack out of proposed structure?

**RESPONSE:**

*Top of manhole = 230 feet.  
New OA pipe to the pump station = 224 feet  
Manhole base = 210 feet  
Existing pipe at new manhole = 214.75 feet*

- E.** What are the elevations for the cores at the pump station as well as the invert elevation for the proposed 24" coming out of the proposed manhole?

**RESPONSE:**

*Both cores = 219.5 feet  
Manhole outlet = 224.0 feet*

- F.** Does Loudoun Water foresee the need for blasting?

**RESPONSE:**

*No blasting is needed. The site was blasted during construction of the plant.*

- G.** Will a performance bond be required?

**RESPONSE:**

*Loudoun Water does not anticipate a performance bond at this time.*

- H.** How will the contractor gain access to the site?

**RESPONSE:**

*The truck entrance will be used. A temporary gate card will be provided to the contractor.*

- I.** Will there be a staging area available during construction?

**RESPONSE:**

*Yes.*

- J. Will the contractor be responsible for removal of the spoil (dirt) leftover from the construction?

**RESPONSE:**

No.

- K. **Appendix B – Manhole** Are substitutions permitted?

**RESPONSE:**

No.

**4. CLARIFICATION**

- A. The wetwells are raw sewage. The contractor must provide gas monitors if the contractor needs to get inside the wetwells. It is the contractor's responsibility for Safety compliance. Please refer to Section 5, Contract Conditions, item J, Safety.
- B. Miss Utility will mark the electric and gas lines. Loudoun Water will mark the water and sewer lines. There are no other underground utilities near the site.
- C. Attachment 1 – Contractor Provided Materials. The quantity listed is **estimated**; actual quantities may be greater than or less than as stated in Attachment 1.
- D. **Return the following forms (pages) to Loudoun Water with the Revised Bid Form, page 6, Attachment 2:**
- Page 14 of the original IFB, References
  - Page 15 of the original IFB, Offeror Identification and Ownership Disclosure
  - Page 16 of the original IFB, Rider Clause
  - Page Acknowledgement of Addendum No. 1, Attachment 1, page 5

**5. ATTACHMENTS**

The following items are attached and considered part of this Addendum:

- Attachment 1 – Acknowledgement of Addendum No. 1
- Attachment 2 – Revised Bid Form
- Attachment 3 – Pre-Bid Meeting Attendee List

Prepared by: Bessie Nelson, Purchasing Technician

**Attachment 1  
ACKNOWLEDGEMENT OF ADDENDUM No. 1**

**Invitation for Bid –2011-052-240  
Odorous Air Pipe Repair**

The undersigned acknowledges that Addendum No. 1 for IFB No #2011-052-240 Odorous Air Pipe Repair has been received by the undersigned and will be incorporated in all copies of bids from the undersigned.

It is understood that all bids submitted in response to this project will be presumed to be based upon full knowledge of the contents of Addendum No. 1.

---

This Addendum consists of 7 pages, including cover page.

My signature below acknowledges receipt of Addendum 1, and certifies that my bid submission includes all information, modifications, additions or deletions pertaining to this Addendum and the original IFB.

Legal Name of Firm: \_\_\_\_\_

Authorized Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Name and Title (Typed): \_\_\_\_\_

**Return this page with Bid**

**Attachment 2**

**REVISED BID FORM**

**Invitation for Bid –2011-052-240  
Odorous Air Pipe Repair**

Extended Due Date: **Thursday, February 2, 2012 at 3:00 p.m. (Eastern Time)**

The Contractor agrees to perform all work described in the Invitation for Bid 2011-052-240, Odorous Air Pipe Repair and subsequent Addenda for the following Total Lump Sum Price:

**FIRM FIXED PRICE - LUMP SUM PRICE:**

The lump sum of

\$ \_\_\_\_\_ Dollars \_\_\_\_\_ Cents  
(Write lump sum price in words)

\$ \_\_\_\_\_  
(Numerical)

By my signature on this solicitation, I certify that this firm/individual is properly licensed for providing the goods/services specified and will comply with all terms and conditions of the IFB and Addenda. I agree to furnish the goods/services at the Firm Fixed Price indicated and it is understood that Loudoun Water will not be accepting any price change orders.

Respectfully Submitted:

_____	_____
Signature	Address
_____	_____
Printed Name	
_____	_____
Title	
_____	_____
Date	Federal Employer's Identification No.
_____	_____
Virginia License No.	Type

**Return this page with Bid**

