



NOTES:

1. 4 - #10 THWN - 1" C. PVC CONDUIT TO PUMP SUB PANEL (TYPE "A") OR
4 - #10 UF - 3/4" C. PVC CONDUIT TO PUMP SUB PANEL (TYPE "B").
2. NEW #6 AWG. SUPPLEMENTARY GROUND CONDUCTOR TO NEW 3/4" X 10'-0" GROUND ROD.
3. ELECTRIC TO MEET ALL LOCAL CODES. OWNER TO OBTAIN ELECTRICAL PERMIT.
DEDICATED CIRCUIT REQUIRED.
4. REFER TO APPROVED PRODUCTS LIST FOR ADDITIONAL REQUIREMENTS.

03/27/06

GRINDER PUMP ELECTRICAL SUPPLY

S4A