



NOTES:

1. TRENCH WIDTH IN EARTH TO BE PIPE O.D.+12"
TRENCH WIDTH IN ROCK TO BE PIPE O.D.+48"
2. ENCASEMENT:
 - A. BEGIN AND END ENCASEMENT AT PIPE JOINT.
 - B. CONCRETE TO BE LCSA CLASS B (3000 PSI).
 - C. BUOYANCY CALCULATIONS REQUIRED FOR PIPES LARGER THAN 12" OR IF ENCASEMENT IS TO BE LONGER THAN 60'.
3. REQUIREMENTS FOR PIPE 30 IN. DIAMETER AND GREATER SHALL BE ON A JOB SPECIFIC BASIS.
4. REFER TO APPROVED PRODUCTS LIST FOR ADDITIONAL REQUIREMENTS

01/12/06

PIPE BEDDING AND ENCASEMENT

G1