



**NOTES:**

1. ALL FIRE LINES TO BE DUCTILE IRON WITH A MIN. SIZE OF 3".
2. UTILIZE DOG-EAR, DUC LUGS, OR TWISTED EYE BOLTS FOR ALL RODDING.
3. ALL-THREAD RODS TO BE 3/4" DIAMETER BITUMASTIC COATED.
4. FIRE LINE INSTALLATION AND HYDROSTATIC TESTING TO BE WITNESSED BY LCSA (200 PSI FOR 2 HOURS WITH NO LEAKAGE).
5. FLUSHING TO BE WITNESSED BY LOUDOUN COUNTY FIRE MARSHALL. CONTACT LOUDOUN COUNTY BUILDING AND DEVELOPMENT AT (703) 777-0397.

06/02/02

FIRE LINE

W1