



NOTES:

1. REFER TO APPROVED PRODUCTS LIST FOR ADDITIONAL REQUIREMENTS.
2. SEE DETAIL W10A FOR TAPS ON 3" OR 4" MAINS.
3. a. WHEN AT CURB, LID TO BE FLUSH TO NO MORE THAN 1" ABOVE CURB.
 b. WHERE THERE IS NO CURB, LID TO BE 1" ABOVE FINAL GRADE.
 c. IN SLOPES, RETAINING WALL TO BE PLACED MINIMUM 3'-0" FROM LID.

06/02/02

SERVICE CONNECTION FOR
(5/8", 3/4" & 1" METERS)

W12