



NOTES:

1. REFER TO APPROVED PRODUCTS LIST FOR ADDITIONAL REQUIREMENTS.
2. METER TO BE FURNISHED BY LCSA & INSTALLED BY CONTRACTOR.
3. THE BUILDING'S INTERNAL PLUMBING SHALL INCLUDE A BACK FLOW PREVENTOR (CERTIFIED BY A.S.S.E. OR C.S.A.). INSTALATION & TESTING SHAL BE IN ACCORDANCE WITH THE 2003 INTERNATIONAL PLUMBING CLODE (INCLUDING BUT NOT EXCLUSIVELY SECTIONS 312.9.2, 608.2, & 608.3) & L.C.S.A.'S CROSS CONNECTION/BACKFLOW PREVENTION MANUAL. SYSTEMS THAT REQUIRE AN R.P.Z. BACK FLOW PREVENTOR SHALL HAVE, AT A MINIMUM, AN EQUIVALENTLY SIZED DRAIN. FOR MORE DETAILS & INSPECTION REQUIREMENTS, CALL L.C.S.A.'S BACK FLOW SPECIALIST AT (703) 729-7878.
4. SEE DETAIL W15 FOR TURBINE METER SETTINGS.
5. COPPER (TYPE K) SERVICE LINE. ONE PIECE, INLINE COUPLINGS NOT PERMITTED, MAXIMUM LENGTH 50- FEET. USE FLARE CONNECTIONS ONLY.

03/27/06

WATER METER & SERVICE CONNECTION (1 1/2" & 2")

W15