



NOTES:

1. OWNER TO PROVIDE BACKFLOW PREVENTER IN SERVICE LINE AS PART OF THE BUILDING'S INTERNAL PLUMBING. CALL LCSA BACKFLOW SPECIALIST AT (703) 729-7878 FOR DETAILS AND INSPECTION REQUIREMENTS.
2. WATER METER SUPPLIED BY LCSA, INSTALLED BY CONTRACTOR.
3. VALVES TO BE GATE VALVES OR BALL VALVES.
4. WATER ROOM MUST HAVE EXTERIOR DOOR OR SLEEVE THROUGH WALL TO ALLOW A HOSE TO BE STRUNG TO OUTDOORS.
5. IF DISTANCE NOT AVAILABLE, PUT METER OUTSIDE IN VAULT.
6. FLOOR DRAIN RECOMMENDED.

06/02/02

INSIDE METER SETTING

W17