



NOTES:

1. INSIDE CEILING HEIGHT TO BE 6'-6" MIN. PIPE CENTERLINE 3'-0" ABOVE FLOOR.
2. ALL PIPE TO BE FLANGED DUCTILE IRON.
3. UTILIZE BILCO 36"X36" HINGED FRAME AND COVER MODEL J-4AL OR APPROVED EQUAL.
4. STRUCTURAL DESIGN TO BE CERTIFIED BY VIRGINIA PROFESSIONAL ENGINEER.
5. TAP AT MAIN IS TO BE VALVED AND RESTRAINED/ 6-INCH MINIMUM.
6. REFER TO APPROVED PRODUCTS LIST FOR ADDITIONAL REQUIREMENTS.
7. SLOPE FLOOR TO SUMP.
8. VALVES TO BE RESILIENT WEDGE GATE VALVES OR BALL VALVES. PROVIDE HAND WHEEL OPERATORS.

MINIMUM DIMENSIONS:

METER SIZE	A	B
3"	9'0"	7'0"
4"	9'0"	7'0"
6"	12'0"	8'0"

06/02/02

METER VAULT

W18