



NOTES:

1. BED COPPER TUBING IN 78 STONE. EXTEND STONE TO BASE OF SAMPLING STATION.
2. BALL CORP & SERVICE VALVE TO HAVE FLARED CONNECTIONS.
3. REFER TO APPROVED PRODUCTS LIST FOR ADDITIONAL REQUIREMENTS.

06/02/02

SAMPLING STATION

W23