



NOTES:

1. BLOCKING FOR PIPE LARGER THAN 16" SHALL BE REVIEWED AND APPROVED ON AN INDIVIDUAL BASIS BY THE AUTHORITY'S ENGINEER.
2. CONCRETE STRENGTH SHALL BE LCSA CLASS B (3000 PSI).

06/02/02	OFFSET BLOCKING	W5B
----------	-----------------	-----