



NOTES:

1. BEARING AREA IS BASED ON 200 PSI TEST PRESSURE AND A SOIL BEARING PRESSURE OF 2000 POUNDS PER SQUARE FOOT. INCREASE BLOCK DIMENSIONS AS REQ'D. FOR HIGHER TEST PRESSURES AND IN SOILS WITH LOWER BEARING VALUES.
2. *DIMENSIONS "B" AND "D" ARE MINIMUM VALUES FOR BEARING IN UNDISTURBED EARTH.
3. REFER TO APPROVED PRODUCTS LIST FOR ADDITIONAL REQUIREMENTS.
4. CONCRETE STRENGTH SHALL BE LCSA CLASS B (3000 PSI).

DEAD END ANCHOR SCHEDULE				
LINE SIZE	A	B*	C	D*
16"	2'-9"	3'-0"	2'-0"	1'-6"
24"	3'-6"	4'-0"	2'-6"	2'-0"

06/02/02

DEAD END ANCHOR
(16" & 24" LINE SIZE)

W6A