



NOTES:

1. FIELD PAINTING OF HYDRANT REQUIRED.
2. REFER TO APPROVED PRODUCTS LIST FOR ADDITIONAL REQUIREMENTS.
3. FIRE HYDRANT TO BE A MINIMUM 5'-0" FROM ALL ENTRANCES.
4. LANDSCAPING NOT PERMITTED WITHIN 5'-0" OF HYDRANTS.
5. WEEP HOLES SHALL BE FREE OF CONCRETE AND POLYETHYLENE.

06/02/02

FIRE HYDRANT
ALONG STREETS

W8