



NOTES:

1. FIELD PAINTING OF HYDRANT REQUIRED.
2. REFER TO APPROVED PRODUCTS LIST FOR ADDITIONAL REQUIREMENTS.
3. FIRE HYDRANT TO BE A MINIMUM 5'-0" FROM ALL ENTRANCES.
4. SEE DETAIL W9 FOR DIMENSIONS.
5. SERVICE TAPS NOT PERMITTED UPSTREAM OF DEAD END ANCHOR.
6. LANDSCAPING NOT PERMITTED WITHIN 5'-0" OF HYDRANT.

06/02/02

DEAD END HYDRANT

W9