

ADDENDUM NO. 1
September 22, 2010

PROJECT: Broad Run Water Reclamation Facility Solar Demonstration Project
Project ID: 20100033
Virginia DEQ Project Identifier C-515451G

OWNER: Loudoun County Sanitation Authority (dba Loudoun Water)
44865 Loudoun Water Way
Ashburn, VA 20147

ENGINEER: CH2M Hill
15010 Conference Center Drive, Suite 200
Chantilly, VA 20151

The purpose of the addendum is to extend the bid due date to **September 28, 2010** as per section 00100 of the Invitation For Bid.

Bid Opening Date: Tuesday, September 28, 2010
and Time: 2:00 p.m. local time (eastern time)

The following changes, additions, clarifications and drawings are hereby made part of the Contract Documents for the above referenced project and shall be taken into account in the preparation of all bids and the execution of all work. Bidders shall acknowledge receipt of this addendum in the appropriate space on the Bid Form.

SPECIFICATIONS

Make the following additions, deletions or other changes to the Contract Documents:

1. Section 00100 – Invitation to Bid
REPLACE “August 5” **WITH** “September 3”.

2 . Section 00100 – Invitation to Bid
REPLACE “September 20” **WITH** “September 28”.

PLANS

Make the following additions, deletions or other changes to the Contract Documents:

1. Drawing E-3
PV Array 2 is shown with 24 panels. **REPLACE** the 24 panels **WITH** 22 panels because the maximum number of panels per inverter is 11.