

Month June**Raspberry Falls Well Water Plant**Year 2011**Additional Testing to Evaluate Possible Surface Water Influence to #2 Well**

Date	Well #2 water usage GPD	Rain Gauge Reading	PH	Temperature	Conductivity	Turbidity	RAW WATER MPN - TC	RAW WATER MPN - EC	Amount pumped just prior to testing.	CL2 Residual
1	103400	0.0								
2	91900	0.0	8.0	15.4	206.8	0.1	3.1	<1	running	1.5
3	55300	0.0								1.7
4	93200	0.2								
5	92100	0.0								
6	104000	0.0	7.9	14.5	201.5	0.1	1.0	<1	running	1.8
7	132900	0.0								
8	129000	0.0	7.8	16.2	208.8	0.1	3.1	1.000	running	1.8
9	104400	0.4								
10	79500	0.0								
11	125200	0.0								
12	104300	0.5								
13	71000	0.0	7.7	15.2	203.6	0.1	<1	<1	running	1.9
14	65100	0.0								
15	123700	0.0	7.7	14.0	198.2	0.2	<1	<1	running	1.6
16	81400	0.0								
17	81900	0.5								
18	93800	0.0								
19	67500	0.2								
20	75100	0.0	7.9	14.6	201.1	0.2	<1	<1	running	1.7
21	78500	0.0								
22	98700	0.0								
23	92900	0.0	7.7	14.4	200.2	0.2	<1	<1	running	1.7
24	101600	0.0								
25	119900	0.0								
26	122800	0.0								
27	71900	0.0								
28	94900	0.8								
29	80800	0.0	7.7	14.5	200.2	0.2	<1	<1	running	1.6
30	117600	0.0								
31										
AVG	95143	0.1	7.8	14.9	202.6	0.2	2.4	1.000	#DIV/0!	1.7
TOT	2854300	2.5	62.4	118.8	1620.4	1.3	7.2	1.000	0.0	15.3
MAX	132900	0.8	8.0	16.2	208.8	0.2	3.1	1.000	0.0	1.9

Comments and observations: