

Month September**Raspberry Falls Well Water Plant**Year 2011**Additional Testing to Evaluate Possible Surface Water Influence to #2 Well**

Date	Well #2 water usage GPD	Rain Gauge Reading	PH	Temperature	Conductivity	Turbidity	RAW WATER MPN - TC	RAW WATER MPN - EC	Amount pumped just prior to testing.	CL2 Residual
1	81000	0.00								
2	62600	0.00								
3	78900	0.13								
4	77800	0.00								
5	54300	1.15								
6	44800	1.34								1.8
7	36400	0.97								
8	43000	0.98	7.7	14.7	213.0	0.2	<1	<1	2100.0	1.8
9	45000	0.11								
10	47500	0.00								
11	48800	0.59								
12	46600	0.02	7.8	15.1	209.3	0.1	<1	<1	3700.0	2.3
13	65100	0.00								
14	37000	0.65								
15	37800	0.01								
16	53800	0.02								
17	51100	0.02								
18	71100	0.01								
19	37500	0.16								
20	60700	0.03	7.9	14.9	213.4	0.1	<1	<1	1900.0	2.3
21	34700	0.60								
22	50600	0.03								
23	28500	0.31								
24	49200	0.00								
25	55600	0.00								
26	45300	0.00								
27	52100	0.39	7.9	15.4	215.1	0.2	3.1	<1	2000.0	2.1
28	40100	0.71								
29	45500	0.01								
30	52700	0.50								
31										
AVG	51170	0.3	7.8	15.0	212.7	0.1	3.1	#DIV/0!	2425.0	2.1
TOT	1535100	8.7	31.3	60.1	850.8	0.5	3.1	0.000	9700.0	10.3
MAX	81000	1.3	7.9	15.4	215.1	0.2	3.1	0.000	3700.0	2.3

Comments and observations: