

Month January**Raspberry Falls Well Water Plant**Year 2011**Additional Testing to Evaluate Possible Surface Water Influence to #2 Well**

Date	Well #2 water usage GPD	Rain Gauge Reading	PH	Temperature	Conductivity	Bacteriological Result As MPN Total/E.coli	Particulate Analysis	Turbidity	Amount pumped just prior to testing.	CL2 Residual
1	40300	0.00								
2	32300	0.00								
3	39000	0.00	7.7	11.8	214.6	<1 / <1		0.353	1100	1.5
4	32900	0.00								
5	36700	0.00								
6	26200	.75 snow								
7	48400	0.00								
8	36600	0.00								
9	29000	0.00								
10	33700	0.00	7.7	11.9	201.2	<1 / <1		0.058	1800	1.4
11	46700	.75 snow								
12	33100	0.00								
13	28700	0.00								
14	26000	0.00								
15	32000	0.00								
16	34900	0.00								
17	35000	.75 ice/snow								
18	34800	0.00								
19	25300	0.00	7.7	12.2	208.8	<1 / <1		0.094	2500	1.5
20	34200	0.00								
21	28100	0.00								
22	33600	0.00								
23	38300	0.00								
24	31400	0.00	7.7	12.2	199.9	<1 / <1		0.052	1200	1.4
25	25900	0.20								
26	25500	1.0 snow								
27	39400	0.00								
28	22700	0.00								
29	37400	0.00								
30	34500	0.00								
31	34900	0.00	7.5	12.6	202.3	<1 / <1		0.116	well on	1.8
AVG	33468	0.0	7.7	12.1	205.4	#DIV/0!	#DIV/0!	0.135	1650	1.5
TOT	1037500	0.2	38.3	60.7	1026.8	0.0	0.0	0.673	6600	7.6
MAX	48400	0.2	7.7	12.6	214.6	0.0	0.0	0.353	2500	1.8

Comments and observations:**ENTRY POINT P/A RESULTS = ABSENT**