

Month March**Raspberry Falls Well Water Plant**Year 2011**Additional Testing to Evaluate Possible Surface Water Influence to #2 Well**

Date	Well #2 water usage GPD	Rain Gauge Reading	PH	Temperature	Conductivity	RAW WATER MPN - TC	RAW WATER MPN - EC	Turbidity	Amount pumped just prior to testing.	CL2 Residual
1	27600	0.00								
2	26000	0.00								
3	31200	0.00								
4	20400	0.00								
5	40300	0.13								
6	28700	2.12								
7	26600	0.00	7.7	11.3	213.3	<1	<1	0.052	2700	1.6
8	34600	0.02								
9	26600	1.00								
10	22600	1.30								
11	29400	0.00								
12	37200	0.00								
13	32100	0.00								
14	28000	0.00	7.9	12.5	205.3	<1	<1	0.260	2100	1.2
15	27900	0.33								
16	28400	0.00								
17	34300	0.00								
18	23300	0.00								
19	34900	0.00								
20	37900	0.20								
21	25000	0.00	7.8	12.6	208.9	2.0	<1	0.060	2100	1.4
22	34800	0.80								
23	26400	0.38								
24	28900	0.00								
25	31000	0.00								
26	31400	0.10								
27	37000	0.00								
28	30900	0.00	7.5	13.0	201.7	1.0	<1	0.1	3100	1.4
29	31600	0.00								
30	25400	0.20								
31	34000	0.28								
AVG	30142	0.2	7.7	12.4	207.3	1.5	#DIV/0!	0.1	2500.0	1.4
TOT	934400	6.9	30.9	49.4	829.2	3.0	0.0	0.4	10000.0	5.6
MAX	40300	2.1	7.9	13.0	213.3	2.0	0.0	0.3	3100.0	1.6

Comments and observations:
ENTRY POINT P/A RESULTS =