

**LOUDOUN COUNTY SANITATION AUTHORITY  
(DBA LOUDOUN WATER)**

44865 Loudoun Water Way  
Ashburn, Virginia 20147  
Telephone: 571-291-7700

24" WATERLINE RELOCATED ROUTE 621 TO TALL CEDARS PARKWAY RED DOT 24  
PROJECT ID NO. 20100015

**NOTICE OF ADDENDUM**

ADDENDUM NO. 1  
FEBRUARY 10, 2011

Bidders on the above-named Project are hereby notified the documents have been revised as indicated below. All bid submittals shall conform to this Addendum. Bidders are responsible for familiarizing themselves with these modifications and the effect they may have on the scope of work.

**CONTRACT DOCUMENTS AND PROJECT DRAWINGS**

1. Contract Document, page 00100-1 – extension of BID
  - BIDS will be received by Loudoun Water (OWNER) until 2:00 PM on March 2, 2011. BIDS received after this time will not be accepted.
2. Project Drawings Sheets 5, 7, and 9 of 24 – 24" water Restrained Joint Pipe clarification
  - Restrained Joint Pipe for all 24" water between stations 24+00 to 27+75, stations 49+00 to 52+84, including east of station 49+97 and west of station 52+64, stations 57+40 to 60+62, and stations 75+15 to 77+54 will be of Model Name Flex-Ring®, TR Flex, or Snap-Lok™ per the Loudoun Water Approved Products List. FieldLok 350 Gasket and Mechanical Joint Pipe with restraining glands are not acceptable restraints for the above named stations. Valves and fittings within the aforementioned stations are to have mechanical joint ends and to be installed with approved restraining glands.
3. Contract Document, page 02510-9, paragraph 3.07A and Project Drawing Sheet 16 of 24
  - Spacing for marker posts shall be every 300'-500' per Loudoun Water Standard Detail G15 and use this same spacing for outer limits of easement.

4. Contract Document, page 02315-9, paragraph 3.06D and Project Drawings Sheets 16 and 17 of 24
  - For private roads Youngwood Lane from station 91+00 to 111+00 and Briarfield Lane station 111+00 to 128+80, follow the backfill requirements of Loudoun Water Standard Detail G-13 on sheet 16 of 24 and the dimension requirements of the Pavement Repair Detail on sheet 17 of 24.
5. Contract Document, page 00410-1, last paragraph, and page 00520-1, item 1, last sentence are amended as follows
  - BIDDER agrees to pay as liquidated damages, \$10,000.00, for each calendar day beyond 260 consecutive calendar days after the NOTICE TO PROCEED until SUBSTANTIAL COMPLETION is achieved, as provided in Section 15 of the General Conditions.
6. Contract Documents and Project Drawings – clarification
  - BID is for furnishing water main and associated appurtenances described within Contract Documents and Project Drawings and does not include any sanitary or storm sewer facilities.

END OF ADDENDUM NO. 1