



# Drinking Water Quality

**ANNUAL REPORT**

For the year ending 2022

**Central System**



## Introduction

Loudoun Water is pleased to present your drinking water quality annual report. The information contained in this report is based on data collected and reported to Virginia Department of Health in 2022, unless otherwise noted.

Annual dissemination of this report is required under the federal Safe Drinking Water Act (SDWA). Established to safeguard the quality of drinking water across the United States, the SDWA establishes contaminant level limits in drinking water. These limits are represented in this report as MCLs, or Maximum Contaminant Levels. A glossary of helpful definitions is listed on the following page.

Based on rigorous sampling, the data tables prepared for this report provide important information about the quality of your drinking water throughout the year. On page 10, **Table One** shows the quality of the water as it flows within the Loudoun Water distribution system; and on page 11 **Table Two** shows the quality of the water as it leaves the treatment plants that supply our water.

If you have a question or concern that is not addressed in this report, please contact us at 571-291-7880. Our staff is available to assist you Monday through Friday between 8:00 a.m. and 5:00 p.m. You may also contact us at any time to obtain the latest drinking water quality data. Previous drinking water quality reports and additional water quality information can be found at [www.loudounwater.org](http://www.loudounwater.org).

We also invite you to attend our monthly Loudoun Water Board Meetings, which are usually held on the second Thursday of each month in the Boardroom of our Dale C. Hammes Administration Building, located at 44865 Loudoun Water Way, Ashburn, VA 20147. To learn more about Loudoun Water's Board of Directors, please visit [www.loudounwater.org/about](http://www.loudounwater.org/about).



@loudounwater



## Helpful Definitions

**Action Level:** The concentration of a contaminant which, if exceeded, triggers a treatment or other requirement that a water system must follow.

**Level 1 Assessment:** An evaluation to identify the possible presence of sanitary defects, defects in distribution system coliform monitoring practices, and, when possible, the likely reason that the waterworks triggered the assessment.

**Level 2 Assessment:** An evaluation to identify the possible presence of sanitary defects, defects in distribution system coliform monitoring practices, and, when possible, the likely reason that the waterworks triggered the assessment in a more comprehensive investigation than a Level 1 assessment.

**Maximum Contaminant Level (MCL):**

The highest level of a contaminant that EPA allows in drinking water. MCLs are set as close to the MCLGs as possible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG):**

The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):**

The maximum permissible level of disinfectant residual in drinking water, based on a running annual average.

**Maximum Residual Disinfectant Level Goal**

**(MRDLG):** The level of a drinking water disinfectant below which there is no known or expected health risk. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**mrems/year:** Millirems per year. A measurement of radiation absorbed by the body.

**N/A:** Not applicable.

**ND:** Non-detect. Concentration levels so low they were not detectable.

**Ninetieth (90th) Percentile:** Represents the highest value found out of 90 percent of the samples taken in a representative group. If the 90th percentile is greater than the action level, it will trigger a treatment or other requirement that a water system must follow.

**NTU:** Nephelometric Turbidity Unit.

**PCi/L:** Picocuries per liter.

**PMCL:** Primary maximum contaminant level of a contaminant based on health considerations.

**ppb:** Parts per billion. One ppb is equal to one microgram per liter (ug/L).

**ppm:** Parts per million. One ppm is equal to one milligram per liter (mg/L).

**Total Coliform:** Bacteria that indicate whether other potentially harmful bacteria may be present.

**TT:** Treatment Technique. A required process intended to reduce the level of a contaminant in drinking water.



### Letter from the General Manager

I am proud to present our Annual Water Quality Report covering the period between January 1 and December 31, 2022. This report is a snapshot of last year's water quality. It includes details such as where your water comes from, what it contains, and how it compares to rigorous standards set by regulatory agencies.

I have the pleasure of reporting that Loudoun Water either met or exceeded standards set by the EPA and administered by the Virginia Department of Health in 2022. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

I hope you will find the Loudoun Water Annual Drinking Water Quality Report useful and informative. If you have any questions about this report or your drinking water quality, I encourage you to contact our Customer Relations team at 571-291-7880 or via email at [customerservice@loudounwater.org](mailto:customerservice@loudounwater.org). Our staff at Loudoun Water are always here for you and are happy to help.

Sincerely,

**Carla P. Burleson**

General Manager



## Letter from the Chairman

As Chairman of the Loudoun Water Board of Directors, it is my great pleasure to share our Annual Drinking Water Quality Report. This report provides an extensive list of what we test for in your water and information on the treatment that is used to ensure its safety and maintain compliance with U.S. Environmental Protection Agency and Virginia Department of Health standards.

We value your trust and remain committed to providing exceptional drinking water and reliable service to you and your family. As we look toward the future, Loudoun Water will continue to identify and invest in system improvements and technologies that will allow us to increase efficiencies and ensure the safety, reliability, and sustainability of our water supply for many generations to come.

I encourage you to reach out to the Loudoun Water staff about any questions you may have about your drinking water or utility operations. I want to thank you for taking the time to read through this report. For additional information about Loudoun Water or projects in your community, please visit [www.loudounwater.org](http://www.loudounwater.org).

Sincerely,

**Mark Koblos**

Chairman, Loudoun Water Board of Directors





### About Loudoun Water

Our mission is to work to ensure a healthy environment and high quality of life through effective and sustainable management of resources entrusted to our care. Loudoun Water is committed to providing excellent water, wastewater and reclaimed water services for all our customers in a dynamic county that continues to grow and evolve at a rapid pace. Loudoun Water is preparing for the future; one of continued county expansion, economic growth, adaptable technologies, and enhanced public health and safety. With sustained regional growth, major investments in water infrastructure, and deployment of advanced operational and informational technologies, Loudoun Water remains a proactive resource and partner in our vibrant county.

To do this, Loudoun Water maintains over 1,400 miles of water distribution pipelines, over 1,200 miles of wastewater collection system pipelines and a growing reclaimed non-potable water system.

Loudoun Water is a political subdivision of the State and is not a department of Loudoun County. This means all Loudoun Water income is received either as user fees from customers, which go towards operating expenses or as developer fees which are used to pay for capital improvements.

Loudoun Water is governed by a Board consisting of nine members appointed by the Board of Supervisors. The Board members serve four-year terms and can be reappointed by the County. The Board appoints the General Manager, who is responsible for the daily management of Loudoun Water.

Loudoun County is a rapidly growing jurisdiction located in the northern tip of the Commonwealth of Virginia approximately 25 miles northwest of Washington, D.C. Loudoun County contains 517 square miles, making it one of the largest counties in the region. It has been one of the fastest growing counties in the country over the past decade. The County is expected to continue to have one of the highest population and employment growth rates in the entire Washington, D.C. region over the next 20 years. Loudoun Water continues to plan for this growth, which is outlined in our Capital Improvement Plan.



# SOURCE WATER ASSESSMENT

Since the Loudoun Water system has two sources of water (Potomac River and Goose Creek), two source water assessment reports have been conducted by the Virginia Department of Health. These reports consist of maps showing the source water assessment areas, an inventory of known land-use activities of concern and documentation of any known contamination. Based on state criteria, both sources are considered to be highly susceptible to contamination. Additional information about these reports can be obtained by contacting us at 571-291-7880.

## Your Water Sources

Your drinking water comes from the Potomac River and as needed Goose Creek. The Potomac River is augmented by reservoirs in Maryland, Virginia, and West Virginia through a shared supply agreement with neighboring water providers. Goose Creek receives water from Beaverdam Reservoir and Goose Creek Reservoir. Beaverdam Reservoir fills Goose Creek Reservoir when water levels get low and vice versa. Your drinking water from the Potomac River was fully treated by Loudoun Water and by our wholesaler, Fairfax Water. Drinking water from Goose Creek can be fully treated by Loudoun Water if supplemental drinking water is required.

## What is in Your Water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency (EPA) Safe Drinking Water Hotline at 800-426-4791. The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells.



As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material and can pick up substances resulting from the presence of animals or human activity. Contaminants that may be present in the water include:

- ◆ Microbes (viruses or bacteria) from septic systems, agricultural livestock operations, wildlife and wastewater treatment plants.
- ◆ Inorganics, such as salts and metals, which can occur naturally or result from stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.



- ◆ Pesticides and herbicides from agriculture, urban runoff and residential uses.
- ◆ Organics (like synthetic and volatile organic chemicals) from industrial processes and petroleum production, gas stations, urban stormwater runoff, and septic systems.
- ◆ Radioactive contaminants, either naturally occurring or the result of oil and gas production or mining activities.

### What Do We Test For?

The Safe Drinking Water Act of 1974 (SDWA), which has been amended most significantly in 1986 and 1996, governs drinking water quality. It sets the limits for contaminants in drinking water. These limits are represented in this report as MCLs, or the Maximum Contaminant Levels. The Food and Drug Administration (FDA) establishes limits for contaminants in bottled water, which must provide the same protection for public health as tap water. Under the SDWA, Loudoun Water is required to test for the presence of a number of organisms and chemicals. We submit the results to the Virginia Department of Health.

- ◆ **Bacteriological analysis** is routinely performed. It is reported based on the presence or absence of total coliform and *Escherichia coliform* (*E. coli*). Their presence indicates potential health risks for individuals exposed to this water. Loudoun Water tested for coliform bacteria at a minimum of 180 locations monthly in 2022.
- ◆ **Total Trihalomethanes (TTHMs) and Haloacetic Acids (HAA5)** analyses are a quarterly monitoring requirement. Both of these form in the water supply as chlorine reacts with organic matter. When ingested in large quantities, these chemicals are suspected human

carcinogens, so we monitor for them closely. The legal limit for TTHMs is a specific location running annual average of 80 parts per billion (ppb). For HAA5, the limit is a specific location running annual average of 60 ppb. Loudoun Water tests for TTHMs and HAA5 at twelve locations throughout the distribution system.

- ◆ **Corrosion control parameters** (orthophosphate and pH) are a semiannual monitoring requirement. By dosing the drinking water with a minimum of 0.90 ppm orthophosphate and maintaining a minimum pH of 7.0, the potential for corrosion of lead, copper and other metals is greatly reduced. Loudoun Water monitors for these corrosion parameters at multiple locations throughout the distribution system.







## Lead in Drinking Water

### WHAT IS THE EPA STANDARD FOR LEAD IN DRINKING WATER?

EPA has established an Action Level for lead in water of 15 parts per billion (ppb). When lead testing is performed as required by EPA, 90 percent of the samples must contain less than 15 ppb. This is usually referred to as the 90th percentile results being less than 15 ppb. The Action Level was not designed to measure health risks from water represented by individual samples. Rather, it is a statistical trigger value that, if exceeded, may require more treatment, public education, and possibly lead to service-line replacement where such lines exist. (Loudoun Water does not have any lead service lines in its system.)

Loudoun Water has been testing for lead and copper in accordance with EPA's Lead and Copper Rule (LCR) since 1992. In 2020, the 90th percentile value for lead was non-detect (ND) or <3 ppb compared to the EPA action level of 15 ppb. Currently, the Virginia Department of Health requires Loudoun Water to monitor for lead and copper at 50 locations every three years.

### WHERE DOES LEAD IN DRINKING WATER COME FROM?

Although some utilities use raw source waters that contain lead, Loudoun Water's sources do not contain lead. In 1986, lead was banned from being used in pipe and solder in home construction. In older homes, where lead is present in pipe and solder connections, it may dissolve into the water after the water sits for long periods.

Some household plumbing components may contain a small amount of lead and can contribute to lead concentrations at the tap. Our water supplier Fairfax Water and Loudoun Water add a corrosion inhibitor to slow this dissolution process.

### WHAT CAN I DO IN MY HOME TO REDUCE EXPOSURE TO LEAD IN THE DRINKING WATER?

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Loudoun Water is responsible for providing high-quality drinking water but cannot control the variety of materials used in plumbing components in home construction. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes, or until it becomes cold or reaches a steady temperature before using the water for drinking or cooking. Use only cold water for drinking, cooking and making baby formula.

If you are concerned about lead in your water, you may wish to have your water tested. Information about lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791)



or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead). Some people choose to install filters in their homes. If you choose to use a water filter, follow these three rules:

1. Choose one designed for the specific filtration desired (chlorine, lead, *Cryptosporidium*, etc.).
2. Make sure the filter is approved by the National Sanitation Foundation ([www.nsf.org](http://www.nsf.org)).
3. Maintain the filter as directed.

### HOW CAN LOUDOUN WATER ASSIST IN HAVING THE WATER IN MY HOUSE TESTED?

For information on having a lead-level test conducted, call our Customer Relations Department at 571-291-7880.

## ARE YOU VULNERABLE TO CONTAMINANTS?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer who are undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their healthcare providers. EPA and Centers for Disease Control and Prevention guidelines on appropriate means to lessen the risk of infections by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 800-426-4791.

### How is Your Water Treated?

The treatment process at both Fairfax Water and Loudoun Water includes chemical coagulation, flocculation, sedimentation, filtration and disinfection. Coagulation and flocculation help condition the raw water so that contaminants combine with particulate matter to form floc (large particles), which will settle out in the sedimentation process. Filtration removes the smaller, lighter particles. Disinfection with chlorine is the last step, which kills bacteria, viruses and other microbial contaminants. Sufficient chlorine is added to deter the growth of bacteria while water flows through the pipes to your home. Chlorine can be dangerous to human health in high amounts. EPA sets the safe limit for chlorine in your water at a running annual average of 4 ppm. The chlorine amount is maintained to be extremely effective at inactivating bacteria.

Chloramine, a type of chlorine, is used as the chlorine disinfectant for both treatment facilities. Chloramines are created by adding ammonia to chlorine. Chloramines break down much slower than free chlorine, minimizing the creation of TTHMs and maximizing the length of time the disinfectant remains in the water. One downside of chloramines is they may cause certain types of gaskets or toilet flappers to deteriorate faster, potentially causing leaks.

Fairfax Water and the Loudoun Water Trap Rock Water Treatment Facility also use ozone as another disinfectant. Ozone reduces the amount of chlorine needed to treat the water, offers additional barriers against waterborne pathogens and produces better tasting water. Orthophosphate is also added to the water to help coat the pipes and reduce the ability of the lead to leach out.



# WATER QUALITY ANALYSIS AND RESULTS

We constantly monitor various components in the water supply to meet all regulatory requirements. The following tables list only those water quality parameters that are regulated and had some level of detection. If you have a question about a parameter not seen here, call us at 571-291-7880.

## Turbidity

Turbidity is the clarity of the water. It is measured in Nephelometric Turbidity Units (NTU). Turbidity higher than 5 NTU is just visually noticeable to the average person. Turbidity has no health effects; however, it can interfere with the disinfection process and provide a medium for microbial growth. Turbidity is measured during the treatment process after the water has been filtered, but before disinfection. The turbidity level of filtered water must be less than or equal to 0.3 NTU in at least 95 percent of the measurements taken each month and no single measurement can exceed 1 NTU.

Turbidity	Average Annual Turbidity (NTU)	Highest Single Measurement (NTU)	Lowest % Of Samples Meeting TT Turbidity Limit	MCL	MCLG	Major Source in Drinking Water	Violation
Fairfax Water—Corbalis Water Treatment Plant	N/A	0.17	100%	TT	N/A	Soil Runoff	No
Loudoun Water—Trap Rock Water Treatment Facility	0.03	0.213	100%				No

Your water is tested for a large array of water quality parameters at locations as it enters into the distribution system. You'll find this data on what was detected in **Table Two**.

Loudoun Water also tests water from within the distribution system for the presence of bacteria, chlorine, total trihalomethanes, haloacetic acids, lead and copper and submits these results to the Virginia Department of Health regularly. This data is found in **Table One**.

The tables on these pages show the results of monitoring for the period of January 1, 2022 to December 31, 2022, unless otherwise noted.



**TABLE ONE: Water Quality in the Distribution System**

Microbial Parameters		Highest Monthly Result	MCL (Max Allowed)		MCLG (Goal)	Typical Source	Violation
Total Coliform Bacteria		0	TT		N/A	Naturally present in environment	No
E. coli Bacteria		0	Repeat sample is E. coli positive OR Routine sample is E. coli positive followed by Repeat sample that is Total Coliform positive OR System fails to take all required repeat samples following E. coli positive routine sample OR System fails to analyze for E. coli when any repeat sample tested positive for Total Coliform		0	Human and animal fecal waste	No
Chemical Parameters		Highest Quarterly System Running Annual Average	MRDL (Max Allowed, Compliance Based on System Running Annual Average)		MRDLG (Goal)	Typical Source	Violation
Total Chlorine (ppm)		3.0	4		4	Water additive used to control microbes	No
		RANGE (individual test results)					
		0.20–4.3					
Disinfection Byproducts		Highest Quarterly Locational Running Annual Average	MCL (Locational Running Annual Average)		MCLG (Goal)	Typical Source	Violation
Total Trihalomethanes (ppb)		41	80		N/A	Byproduct of drinking water disinfection	No
		RANGE (individual test results)					
		6.5–73					
Haloacetic Acids (ppb)		Highest Quarterly Locational Running Annual Average	60		N/A	Byproduct of drinking water disinfection	No
		24					
		RANGE (individual test results)					
		3.8–50					

Metals Parameters	90th Percentile Level	Action Level	Goal	Number of Sites Above Action Level	Typical Source	Violation
Copper (ppm) <sup>1</sup>	0.07	1.3	1.3	0	Corrosion of household plumbing; erosion of natural deposits	No
Lead (ppb) <sup>1</sup>	ND or <3	15	0	0	Corrosion of household plumbing; erosion of natural deposits	No

<sup>1</sup> Data is from 2020.



**TABLE TWO: Water Quality from Loudoun Water Supplier (Fairfax Water) and Loudoun Water**

Water Quality Parameter	Average Amount Detected		MCL (Max Allowed)	MCLG	Typical Source	Violation
	RANGE					
	Fairfax Water Corbalis Water Treatment Facility	Loudoun Water Trap Rock Water Treatment Facility				
Beta/photon emitters¹ (pCi/L)	2.06²	3.02	50	0	Decay of natural and man-made deposits	No
	RANGE					
	ND–ND					
Combined Radium (pCi/L)	N/A	0.834³	5	0	Erosion of natural deposits	No
		RANGE				
		ND–0.834				
Chromium (ppb)	N/A	0.9	100	100	Discharge from steel and pulp mills; erosion of natural deposits	No
Fluoride (ppm)	0.70	0.58	4	4	Water additive which promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories	No
	RANGE					
	0.66–0.75					
Nitrite [as Nitrogen] (ppm)	ND	N/A	1	1	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits	No
	RANGE					
	ND–0.012					
Nitrate [as Nitrogen] (ppm)	1.03	N/A	10	10	Runoff from fertilizer use; leaching from septic tanks; erosion of natural deposits	No
	RANGE					
	0.69–1.35					
Nitrate–Nitrite [as Nitrogen] (ppm)	N/A	1.12	10	10	Runoff from fertilizer use; leaching from septic tanks; erosion of natural deposits	No
Barium (ppm)	0.037	0.045	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits	No
	RANGE					
	0.027–0.050					
Total Organic Carbon⁴ (ratio)	1.1	1.57	TT	N/A	Naturally present in the environment	No
	RANGE	RANGE				
	1.1–1.2	1.00–3.06				

1 The MCL for Beta particles is 4 mrem/year. EPA considers 50 pCi/L to be the level of concern for Beta particles.

2 This radioactive contaminant result is above the analysis-specific detection limit but below the minimum detection limits prescribed in the Consumer Confidence Rule as stated in 40 CFR 141.151 (d).

3 Data is from 2019.

4 Total Organic Carbon (TOC) has no health effects. However, it provides a medium for the formation of disinfection byproducts, including trihalomethanes and haloacetic acids. The maximum contaminant level for TOC is a Treatment Technique (TT), which means there is a required process needed to reduce the level of TOC in the water. The average level reported is a quarterly running average of the monthly ratio of actual TOC removal versus required TOC removal between source and treated waters. This Quarterly Running Annual Average value must be greater than or equal to 1 to be in compliance.

Unregulated Components	Average Amount Detected		MCL (Max Allowed)	MCLG (Goal)	Typical Source	Violation
	RANGE					
	Fairfax Water Corbalis Water Treatment Facility	Loudoun Water Trap Rock Water Treatment Facility				
Sodium <sup>1</sup> (ppm)	16.3	19.1	N/A <sup>1</sup>	N/A <sup>1</sup>	Erosion of natural deposits; runoff from road deicing chemicals; discharge from industrial sources; wastewater treatment plant effluent	N/A <sup>1</sup>
	RANGE					
	11.9–24.2					

1 There are no State or Federal limits established for this parameter.



# INFORMATION ABOUT *CRYPTOSPORIDIUM* IN THE SOURCE WATERS

**THE FOLLOWING INFORMATION REFLECTS DATA GATHERED BY LOUDOUN WATER FOR THE POTOMAC RIVER.**

*Cryptosporidium* is a microbial pathogen sometimes found in surface water throughout the United States. Although filtration removes *Cryptosporidium*, the most commonly used filtration methods cannot guarantee 100 percent removal. Loudoun Water and Fairfax Water consistently maintain their filtration process in accordance with regulatory guidelines to maximize removal efficiency. The monitoring indicates the occasional presence of these organisms in the source water. Current test methods do not allow us to determine whether the organisms are dead or if they are capable of causing disease.

Ingestion of *Cryptosporidium* may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people, infants and small children, and the elderly are at greater risk of developing life-threatening illness. We encourage immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection. *Cryptosporidium* must be ingested in order to cause disease. It may be spread through


means other than drinking water, such as other people, animals, water, swimming pools, fresh food, soils and any surface that has not been sanitized after exposure to feces.

In 2020, Loudoun Water completed monitoring of the Potomac River for compliance with Round 2 of the EPA Long Term 2 Enhanced Surface Water Treatment Rule (LT2ESWTR Round 2). The EPA created this rule to provide for increased protection against microbial pathogens, such as *Cryptosporidium*, in public water systems that use surface water sources. The LT2ESWTR Round 2 monitoring program involves the collection of one sample from water treatment plant sources each month for a period of two years. With the startup of the Loudoun Water Trap Rock Water Treatment Facility in 2018 Loudoun Water has now completed the two year monitoring phase of the Potomac River.

Under the LT2ESWTR Round 2, the average *Cryptosporidium* concentration determines whether additional treatment measures are needed. A *Cryptosporidium* concentration of 0.075 oocysts/liter or greater triggers additional water treatment measures. Loudoun Water and Fairfax Water’s raw water *Cryptosporidium* concentrations have consistently remained below this threshold, therefore no additional treatment measures are required.

The final averaged results for the source water (prior to treatment) at the Potomac River Intakes are as follows:	<i>Cryptosporidium</i> Concentration (oocysts/liter)
Potomac River—Loudoun Water—2019–2020	0.008
Potomac River—Fairfax Water—2015–2017	0.000





## POLY- AND PERFLUOROALKYL SUBSTANCES (PFAS)

### What are PFAS?

Poly- and Perfluoroalkyl Substances, also known as PFAS, are a group of synthetic chemicals that have been in use since the 1940s and there are now more than 4,000 different chemicals in the PFAS family. A wide variety of products, including stain-resistant fabric coatings, non-stick coatings (Teflon), food packaging, and firefighting foam contain PFAS. PFAS manufacturing and processing facilities, facilities using PFAS in production of other products, airports, and military installations are some of the potential contributors of PFAS releases into the air, soil, and water. Due to their widespread use and persistence in the environment, most people in the United States have been exposed to PFAS. Exposure to humans can occur by eating, inhaling, or even touching the product. EPA reports that scientists have found traces of one or more PFAS in the blood of nearly all the people they tested. There is evidence that continued exposure above specific levels to certain PFAS may lead to adverse health effects.

### How is Drinking Water Affected by PFAS?

PFAS can enter drinking water at sites where they are made, used, disposed of, or spilled. PFAS can be found in the air near manufacturing facilities and can enter rainwater. PFAS are very mobile and can be transported through rainwater run-off and enter surface water (rivers, lakes, ponds, etc.) or seep through the soil and migrate into ground water (underground sources of drinking water). Because PFAS are very long-lasting and are not easily broken down by sunlight or other natural processes, they may remain in the environment for many years.

### What is Loudoun Water doing about PFAS?

Loudoun Water has tested for PFAS beginning in 2013, when PFAS chemicals were included in the Unregulated Contaminant Monitoring Rule (UCMR) 3 rule was put into effect. Additionally,



as a wholesale purchaser of drinking water from Fairfax Water, Loudoun Water is working closely in the region to understand PFAS implications as a regional initiative.

In addition to testing, Loudoun Water is paying close attention to US EPA's PFAS drinking water regulatory process. Twenty-nine PFAS chemicals are included in the current UCMR 5 testing, which Loudoun Water will begin in June 2023. In 2016, US EPA issued health advisories for PFOA and PFOS, two specific PFAS chemicals. Based on the new data and EPA's draft analyses, the levels at which negative health effects could occur are much lower than previously understood when EPA issued the 2016 health advisories for PFOA and PFOS. There are currently no enforceable federal drinking water regulations for PFAS chemicals.

Loudoun Water is evaluating and will continue to evaluate treatment processes to treat PFAS in water, and maintain high-quality drinking water for Loudoun Water customers.

### As a Community Member, How Can I Reduce My PFAS Exposure?

- ◆ Check product labels for ingredients that include the words "fluoro" or "perfluoro."
- ◆ Be aware of packaging that contains grease-repellent coatings, such as microwave popcorn bags, fast food wrappers, and single serve convenience snack bags.
- ◆ Avoid or reduce use of non-stick cookware. Stop using products if non-stick cookware shows signs of wear.
- ◆ Avoid stain-resistance and water-proofing treatments. Choose furniture and carpets that aren't marketed as "stain-resistant," and don't apply finishing treatments to these or other items. Avoid clothing, luggage, camping, and sport equipment that were treated for water or stain resistance.





## Explore LW Connect



LW Connect, Loudoun Water's interactive customer system, lets you conveniently access your Loudoun Water account information online.

- Log into your account so you can monitor your water use 24/7.
- Sign up for eBilling Text Alerts for text reminders and alerts.
- Go paperless! Enroll in eBilling and your bill will be emailed to you.

Not an LW Connect user yet? Register online at **[lwconnect.org](http://lwconnect.org)** to get started!

## Learn With Us!

Partnering with area organizations, schools, community members and customers allows Loudoun Water staff to share their knowledge about water and wastewater treatment, conservation, wetlands and more.

Located inside of our Dale C. Hammes Administration Building in Ashburn is an interactive educational center with over 3,500 square feet of indoor exhibits. Come explore "The Aquary," nearly one mile of outdoor trails on our Ashburn campus on your own. School groups, community organizations, scouting groups and HOAs are all welcome to schedule a speaker prior to visiting. Call us at 571-291-7880 for more information or visit our website at **[www.loudounwater.org/community](http://www.loudounwater.org/community)**.

## Outdoor Water Use in The Summer

Loudoun Water recommends wise watering at home. This includes checking your sprinkler settings to avoid overwatering. **For most lawns, 15 minutes of watering is all it takes to maintain a healthy yard.** Too much watering does not help roots grow, promotes mold and wastes water. Excessive watering can also result in a much higher bill.

Loudoun Water recommends the watering schedule below to promote healthy plants and turf. The best time to water your yard is between 6:00 a.m. and 11:00 a.m. to avoid excess evaporation. This watering schedule also spreads out the water demand on our system.

**Even Number Home Addresses:** Thurs & Sun  
**Odd Number Home Addresses:** Wed & Sat

## For Customers with Pools or Irrigation Systems

The Loudoun Water Cross-Connection Backflow Program is responsible for protecting the water distribution system from potential hazards caused by cross-connections of non-potable water systems.

Backflow prevention protects both the customer's drinking water pipes in their home as well as the water mains in the streets. Otherwise, if a pressure drop occurs, any connection to a non-potable source could be siphoned back into the customer's home or Loudoun Water's service line, which is dangerous. The only way to prevent such incidents from occurring and to maintain safe drinking water is to use a backflow prevention device that is correctly installed and maintained properly.

For more information, please contact our Customer Relations department at 571-291-7880 or visit our website at **[www.loudounwater.org](http://www.loudounwater.org)**.



Loudoun Water is committed to ensuring tap water is safe to drink, which according to Federal and State regulations, requires backflow preventers be tested annually by a certified tester to make sure it is adequately working.

### Tap Water for Your Fish Tanks

Customers will need to treat tap water before using it in a fish aquarium because drinking water contains free chlorine and chloramines to inhibit bacterial growth. These disinfectants can harm fish. Check with a local pet store to learn what types of chemicals you need to add to the tank to neutralize the effects of these disinfectants.

## GET INVOLVED WITH SOURCE WATER PROTECTION

Source water is untreated water from lakes, rivers, streams, ponds, reservoirs, aquifers, and springs that serve as a community's water source. Protecting these water sources is an easy way to prevent drinking water from becoming polluted by managing possible sources of contamination.

### How Does Source Water Protection Benefit Me?

- ◆ **Public health protection:** Reduces threats to public health due to acute or chronic illness from exposure to contaminated water.
- ◆ **Economic benefits:** Minimizes cost for water treatment, emergency replacement water and finding new supplies.
- ◆ **Environmental stewardship:** Protects rural lands, wildlife habitats, recreational areas and water quality of streams and wetlands.

### Optimize Your Water Use

The U.S. Environmental Protection Agency's WaterSense® program helps identify a range of certified products that help you use water more wisely as well as save money on your bill. Visit the WaterSense website at [www.epa.gov/watersense](http://www.epa.gov/watersense) to learn more about what you can do to make every drop count. Looking for other ways to save? Visit our website at [www.loudounwater.org](http://www.loudounwater.org) for some creative ways to optimize your water use in the bathroom, kitchen, laundry room and more!

### How You Can Help Protect Source Water:

- ◆ Always pick up after your pet.
- ◆ Refrain from swimming in known drinking water sources.
- ◆ Never dump anything in creeks or lakes.
- ◆ If you like boating, only participate in passive boating such as rowing, canoeing or kayaking instead of motorized boating.
- ◆ Compost yard waste and use natural fertilizers.
- ◆ Plant trees along creeks.
- ◆ Check and repair vehicle fluid levels.
- ◆ Properly dispose of household cleaning products, paint, fertilizers, pesticides and expired/unused medications.



## Notes

[illegible]



## Customer Relations

571-291-7880

## Administration

571-291-7700

## After-Hours Emergencies

571-291-7878

## Have a question about this report?

[www.loudounwater.org/contactus](http://www.loudounwater.org/contactus)

## Miss Utility / VA 811

[www.va811.com](http://www.va811.com)

Dial 811 in Virginia or 1-800-552-7001

**This report contains important information about your drinking water. Translate it, or speak with someone who understands it.**

**If you are a landlord, please share a copy of this report with your tenants.**

يحتوي هذا التقرير على معلومات هامة عن نوعية ماء الشرب في منطقتك. يرجى ترجمته، أو ابحث التقرير مع صديق لك يفهم هذه المعلومات جيداً

### Arabic

Der Bericht enthält wichtige Informationen über die Wasserqualität in Ihrer Umgebung. Der Bericht sollte entweder offiziell übersetzt werden, oder sprechen Sie mit Freunden oder Bekannten, die gute Englischkenntnisse besitzen.

### German

이 보고서는 귀하가 거주하는 지역의 수질에 관한 중요한 정보가 들어 있습니다. 이것을 번역하거나 충분히 이해하시는 친구와 상의하십시오.

### Korean

这份报告中有些重要的信息。讲到关于您所在社区的水的品质。请您找人翻译一下，或者请能看得懂这份报告的朋友给您解释一下。

### Chinese

Questo rapporto contiene informazioni importanti che riguardano la vostra acqua potabile. Traducetelo, o parlate con una persona qualificata in grado di spiegarvelo.

### Italian

Este informe contiene información muy importante sobre su agua potable. Para mas información o traducción, favor de contactar a Customer Service. Telefono: 571-291-7880.

### Spanish

Ce rapport contient des informations importantes sur votre eau potable. Traduisez-le ou parlez en avec quelqu'un qui le comprend bien.

### French

この資料には、あなたの飲料水についての大切な情報が書かれています。内容をよく理解するために、日本語に翻訳して読むか説明を受けてください。

### Japanese

Bản báo cáo có ghi những chỉ tiết quan trọng về phẩm chất nước trong cộng đồng quý vị. Hãy nhờ người thông dịch, hoặc hỏi một người bạn biết rõ về văn đề này.

### Vietnamese



[www.loudounwater.org](http://www.loudounwater.org)  
44865 Loudoun Water Way  
PO Box 4000  
Ashburn, VA 20146



@loudounwater