



NOTES:

1. MATERIALS SUBMITTAL FOR EACH DEVICE MUST BE APPROVED BY LOUDOUN WATER; PRIOR TO FABRICATION AND INSTALLATION.
2. EACH DEVICE MUST BE SIZED IN ACCORDANCE WITH CHAPTER 5 OF LOUDOUN WATER'S ENGINEERING MANUAL AND DESIGNED TO MEET THE REQUIREMENTS CITED IN THE APPROVED MATERIALS LIST.
3. INTERCEPTORS MAY BE MADE OF CONCRETE OR FIBERGLASS REINFORCED PLASTIC.
4. FOR DEVICES WITH MORE THAN 4' OF COVER, PROVIDE MINIMUM 3' ϕ ACCESS SHAFTS, OF WATERTIGHT CONSTRUCTION, WITH INTERLOCKING JOINTS.

AUG.
2018

GREASE INTERCEPTOR

PT-1